

Technical Report

80459-SRL-RP-XT-001-P1

Project

The Laboratory Measurement of The Random Incidence Sound Absorption of Acoustic Panels

Prepared for

Pineapple Contracts

By

Kieron Farrow

Published

23 March 2022

Quality Assurance	
Project Title	The Laboratory Measurement of The Random Incidence Sound Absorption of Acoustic Panels
Document Title	Laboratory Test Report
Client	Pineapple Contracts
Client Address	Westmead Maidstone Kent ME20 6XJ
Author	Kieron Farrow
Checker	Allen Smalls
Report Number	80459-SRL-RP-XT-001-PI

Report Version History

Version	Date	Comments
PI	23/03/2022	



Kieron Farrow


Tester

For and on behalf of

SRL Technical Services Limited

Tel: 01787 247595

Email: kfarrow@srltsl.com



Allen Smalls

Quality Manager

[Contents](#)



0444

This report shall not be reproduced,
except in full, without written approval of
SRL Technical Services Limited

1.0	Description of Test.....	4
2.0	Results.....	5
	Data Sheets 1 to 3.....	6
	Appendix A - Details of Measurements.....	9
	Appendix B – Test Procedure	11
	Appendix C – Measurement Uncertainty	13
	Appendix D – Mounting Methods.....	16

1.0 Description of Test

Tests have been done in SRL's Laboratory at Holbrook House, Sudbury, Suffolk, to determine the random incidence sound absorption of acoustic panels in accordance with BS EN ISO 354:2003 and the single number rating in accordance with BS EN ISO 11654:1997.

The results are given in 1/3rd octave bands over the frequency range 50Hz to 10kHz, which is beyond that required by the test standard. Measurements outside the standard frequency range are not UKAS accredited.

1.1 Description of Sample

One type of acoustic panel was tested. See Section 2.0 and Data Sheets 1 to 3 for more details.

Sampling plan: Enough for test only

Sample condition: New

Details supplied by: Pineapple Contracts

Sample installed by: Pineapple Contracts

1.2 Sample Delivery Date

15 March 2022

1.3 Test Procedures

The sample was mounted/located and tested in accordance with the relevant standard. The details of measurements are given in Appendix A. The method and procedure are described in Appendix B. The measurement uncertainty is given in Appendix C. The mounting methods are described in Appendix D.

2.0 Results

The results of the measurements and subsequent analysis are given in Data Sheets 1 to 3 and summarised below.

Results relate only to the items as received and tested.


SRL Test No.	Description in Brief	Mounting Method	α_w
1	Hush Cork Acoustic Panel 270x270x25mm	A	0.15 (M)
2	Hush Cork Acoustic Panel 270x270x25mm (With Nominally 10mm Gap Between Products)	A	0.20
3	Hush Cork Acoustic Panel 270x270x25mm Laid On 12.5mm Plasterboard	A	0.20 (M)

Data Sheet 1

Laboratory Measurement of Random Incidence Sound Absorption to BS EN ISO 354:2003

Test Number:	I	Test Room:	Empty	With Sample
Client:	Pineapple Contracts	Air Temperature:	15.5 °C	15.4 °C
Test Date:	18/03/2022	Air Humidity:	55 % RH	55 % RH
Chamber Volume:	300.1 m ³	Air Pressure:	1033 mbar	1034 mbar
Mounting Method:	A	Sample Area:	12.32 m ²	
Sample Description: Hush Cork Acoustic Panel 270x270x25mm				

Frequency Hz	T1, empty room reverberation time sec	T2, room reverberation time with sample sec	Sound Absorption Coefficient α_s	Practical Sound Absorption Coefficient α_p
50*	5.30	5.52	-0.03	
63*	4.82	4.65	0.03	n/a
80*	6.42	6.69	-0.03	
100	6.42	6.25	0.02	
125	6.63	6.42	0.02	0.05
160	6.32	5.75	0.06	
200	6.36	5.94	0.04	
250	6.59	5.94	0.07	0.05
315	6.73	5.88	0.09	
400	6.41	4.96	0.18	
500	5.57	3.10	0.57	0.40
630	4.92	3.31	0.39	
800	5.07	4.01	0.21	
1000	5.48	4.93	0.08	0.10
1250	5.44	4.97	0.07	
1600	5.11	4.41	0.12	
2000	4.75	4.10	0.13	0.15
2500	4.23	3.64	0.15	
3150	3.43	2.98	0.17	
4000	2.77	2.45	0.18	0.20
5000	2.18	1.95	0.21	
6300*	1.52	1.37	0.27	
8000*	1.26	1.15	0.28	n/a
10000*	0.86	0.81	0.25	



α_w 0.15(M)

Class Not Classified

Calculated to BS EN ISO 11654:1997

NRC 0.20

Calculated to ASTM C 423-01

* Denotes frequencies outside the range covered by BS EN ISO 354:2003 and not UKAS accredited

v1


Data Sheet 2

Laboratory Measurement of Random Incidence Sound Absorption to BS EN ISO 354:2003

Test Number:	2	Test Room:	Empty	With Sample
Client:	Pineapple Contracts	Air Temperature:	15.5 °C	15.4 °C
Test Date:	18/03/2022	Air Humidity:	55 % RH	54 % RH
Chamber Volume:	300.1 m ³	Air Pressure:	1033 mbar	1034 mbar
Mounting Method:	A	Sample Area:	13.25 m ²	

Sample Description: Hush Cork Acoustic Panel 270x270x25mm (With Nominally 10mm Gap Between Products)

Frequency Hz	T1, empty room reverberation time sec	T2, room reverberation time with sample sec	Sound Absorption Coefficient α_s	Practical Sound Absorption Coefficient α_p
50*	5.30	5.04	0.04	n/a
63*	4.82	4.85	0.00	
80*	6.42	6.76	-0.03	
100	6.42	6.47	0.00	0.00
125	6.63	6.59	0.00	
160	6.32	6.07	0.02	
200	6.36	6.09	0.03	0.05
250	6.59	6.23	0.03	
315	6.73	6.01	0.07	
400	6.41	5.23	0.13	0.35
500	5.57	3.58	0.37	
630	4.92	2.86	0.54	
800	5.07	3.78	0.25	0.15
1000	5.48	4.80	0.10	
1250	5.44	4.98	0.06	
1600	5.11	4.41	0.11	0.15
2000	4.75	3.97	0.15	
2500	4.23	3.58	0.15	
3150	3.43	2.99	0.15	0.15
4000	2.77	2.43	0.17	
5000	2.18	1.93	0.20	
6300*	1.52	1.37	0.23	n/a
8000*	1.26	1.14	0.25	
10000*	0.86	0.79	0.29	



α_w 0.20

Class Not Classified

Calculated to BS EN ISO 11654:1997

NRC 0.15

Calculated to ASTM C 423-01

* Denotes frequencies outside the range covered by BS EN ISO 354:2003 and not UKAS accredited


Data Sheet 3

Laboratory Measurement of Random Incidence Sound Absorption to BS EN ISO 354:2003

Test Number: 3	Test Room: Empty	With Sample
Client: Pineapple Contracts	Air Temperature: 15.5 °C	15.4 °C
Test Date: 18/03/2022	Air Humidity: 55 % RH	53 % RH
Chamber Volume: 300.1 m ³	Air Pressure: 1033 mbar	1034 mbar
Mounting Method: A	Sample Area: 12.32 m ²	

Sample Description: Hush Cork Acoustic Panel 270x270x25mm Laid On 12.5mm Plasterboard

Frequency Hz	T1, empty room reverberation time sec	T2, room reverberation time with sample sec	Sound Absorption Coefficient α_s	Practical Sound Absorption Coefficient α_p
50*	5.30	5.13	0.02	n/a
63*	4.82	4.80	0.00	
80*	6.42	6.74	-0.03	
100	6.42	6.24	0.02	0.05
125	6.63	6.43	0.02	
160	6.32	5.73	0.06	0.10
200	6.36	5.79	0.06	
250	6.59	5.64	0.10	
315	6.73	5.04	0.20	0.45
400	6.41	3.91	0.40	
500	5.57	3.07	0.58	0.15
630	4.92	3.45	0.34	
800	5.07	3.98	0.21	0.15
1000	5.48	4.84	0.10	
1250	5.44	4.83	0.09	
1600	5.11	4.23	0.16	0.20
2000	4.75	3.96	0.16	
2500	4.23	3.59	0.16	n/a
3150	3.43	2.93	0.18	
4000	2.77	2.41	0.18	
5000	2.18	1.89	0.23	n/a
6300*	1.52	1.36	0.23	
8000*	1.26	1.14	0.22	
10000*	0.86	0.79	0.25	



α_w 0.20(M)

Class Not Classified

Calculated to BS EN ISO 11654:1997

NRC 0.25

Calculated to ASTM C 423-01

* Denotes frequencies outside the range covered by BS EN ISO 354:2003 and not UKAS accredited

v1

Appendix A - Details of Measurements

A1. Location

Sound Research Laboratories

Holbrook House

Little Waldingfield

Sudbury

Suffolk

CO10 0TF

A2. Test Date

18 March 2022

A3. Tester

Kieron Farrow of SRL Technical Services Limited

A4. Instrumentation and Apparatus Used

Make	Description	Type
Abtronix	Microphone Multiplexer	
EDI	Microphone Power Supply Unit	
Norwegian Electronics	Multichannel Sound Level Meter	Nor850

Brüel & Kjaer	Windshields	UA0237
	Pre Amplifiers	2669C
	Microphone Calibrator	4231
	Omnipower Sound Source	4296
Larson Davis	12mm Condenser Microphone	2560, 377A60
Oregon Scientific	Temperature & Humidity & Probe	THGR810
TOA	Graphic Equalizer	E-1231
Crown	Class D Amplifier	XLS 1502
G.R.A.S	Pre Amplifier	26AK
	Microphone	40AR

A5. References

BS EN ISO 354:2003	Measurement of sound absorption in a reverberation room.
BS EN ISO 11654:1997	Sound absorbers for use in buildings. Rating of sound absorption.
ATSM C423-01	Sound Absorption and sound Absorption Coefficients by the Reverberation Room

Appendix B – Test Procedure

Measurements of Random Incidence Sound Absorption Coefficients to BS EN ISO 354:2003 - TP14 (Plane Absorbers)

In the laboratory, random incidence sound absorption coefficients are determined from the rate of decay of a sound field in a reverberation room, with and without a test sample installed. The rate of decay is described by the time a sound field takes to decay by 60dB, known as the reverberation time.

The reverberation room is constructed from 215mm brick, which is internally plastered with a reinforced concrete roof and floor. The reverberation room is rectangular, measuring 8.3 metres long, 6.7 metres wide and 5.4 metres high. The volume is 300m³, the total surface area, 275m². From the ceiling hang 10 randomly positioned diffusers, with a total surface area (for one side) of 20m². The room is isolated from the surrounding structure using resilient mountings and seals, ensuring good acoustic isolation.

Using at least two omnidirectional loudspeaker positions, broad band random noise is produced in the room using an electronic generator and power amplifier. When the amplification system is switched off, the decay of sound is filtered into one-third octave band widths and the reverberation times measured. This process is repeated for each of six microphone positions and the values arithmetically averaged to obtain a final value for each frequency.

The sample, which has an area between 10m² and 15.7m², is then laid on the floor of the reverberation room so that no part of it is closer than one metre from any edge of the boundaries. The procedure of measuring the reverberation times then repeated.

The sound absorption coefficients are calculated from the difference in decay rates for each frequency according to the formula:

$$\alpha_s = \frac{A_T}{S}$$

where

- α_s is the random incidence absorption coefficient
- A_T is the increase in equivalent sound absorption area of the test specimen (m²)
- S is the area covered by the test specimen (m²)

The equivalent absorption area of the test specimen is further defined as:

$$A_T = 55.3V \left(\frac{1}{c_2 T_2} - \frac{1}{c_1 T_1} \right) - 4V(m_2 - m_1)$$

where

- V is the volume of the empty reverberation room (m³)
- c₁ is the speed of sound in the empty room (m/sec)
- T₁ is the reverberation time in the empty room (sec)
- m₁ is the power attenuation coefficient calculated according to ISO 9613-1 using the climatic conditions that have been present in the empty room during the measurement.

c₂, T₂ and m₂ have the same meanings as c₁, T₁ and m₁ but with the test specimen in the room.

It is occasionally found that the absorption coefficient derived in this manner reaches a value greater than unity. This is impossible, by definition, and investigation has shown that this anomaly is due to diffraction of the impinging sound waves at the edges of the sample. In practical terms this is insignificant.

Appendix C – Measurement Uncertainty

This Appendix gives the measurement uncertainties for the various sound absorption test measurements. The measurement uncertainties have been calculated in accordance with BS EN ISO 12999-2:2020 and based on repeatability conditions with a coverage factor of k=2.

Weighted sound absorption coefficient, α_w , (according to BS EN ISO 11654)

Expanded measurement uncertainty ± 0.07

1/3 octave band sound absorption coefficient measurements, α_s

Measured sound absorption coefficient, α_s																				
0.00	0.05	0.10	0.15	0.20	0.25	0.30	0.35	0.40	0.45	0.50	0.55	0.60	0.65	0.70	0.75	0.80	0.85	0.90	0.95	1.00

f, Hz	Expanded uncertainties $\pm U$ (k=2)																				
	Derived from BS EN ISO 12999-2:2020 based on repeatability conditions and a coverage factor of k=2																				
50*	n/a																				
63*	0.02	0.05	0.07	0.10	0.13	0.15	0.18	0.21	0.23	0.26	0.29	0.32	0.34	0.37	0.40	0.42	0.45	0.48	0.50	0.53	0.56
80*	0.02	0.04	0.06	0.08	0.10	0.12	0.14	0.16	0.18	0.20	0.22	0.24	0.26	0.28	0.30	0.32	0.33	0.35	0.37	0.39	0.41
100	0.02	0.03	0.05	0.06	0.08	0.09	0.10	0.12	0.13	0.15	0.16	0.18	0.19	0.21	0.22	0.23	0.25	0.26	0.28	0.29	0.31
125	0.02	0.03	0.04	0.05	0.06	0.07	0.08	0.09	0.10	0.12	0.13	0.14	0.15	0.16	0.17	0.18	0.19	0.20	0.21	0.22	0.23
160	0.02	0.03	0.03	0.04	0.05	0.06	0.07	0.08	0.09	0.09	0.10	0.11	0.12	0.13	0.14	0.14	0.15	0.16	0.17	0.18	0.19
200	0.02	0.02	0.03	0.04	0.04	0.05	0.06	0.06	0.07	0.08	0.08	0.09	0.10	0.10	0.11	0.12	0.12	0.13	0.14	0.14	0.15
250	0.02	0.02	0.03	0.03	0.04	0.05	0.05	0.06	0.06	0.07	0.07	0.08	0.08	0.09	0.09	0.10	0.10	0.11	0.12	0.12	0.13
315	0.02	0.02	0.03	0.03	0.04	0.04	0.05	0.05	0.05	0.06	0.06	0.07	0.07	0.08	0.08	0.09	0.09	0.09	0.10	0.10	0.11
400	0.02	0.02	0.03	0.03	0.03	0.04	0.04	0.04	0.05	0.05	0.05	0.06	0.06	0.06	0.07	0.07	0.08	0.08	0.08	0.09	0.09
500	0.02	0.02	0.02	0.03	0.03	0.03	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.07	0.07	0.07	0.08	0.08
630	0.02	0.02	0.02	0.03	0.03	0.03	0.03	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.07	0.07	0.07
800	0.02	0.02	0.02	0.03	0.03	0.03	0.03	0.03	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.07
1000	0.02	0.02	0.02	0.03	0.03	0.03	0.03	0.03	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.07
1250	0.02	0.02	0.02	0.03	0.03	0.03	0.03	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.06	0.07
1600	0.02	0.02	0.03	0.03	0.03	0.03	0.03	0.03	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.06	0.06
2000	0.03	0.03	0.03	0.03	0.03	0.04	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.07	0.07
2500	0.03	0.03	0.03	0.04	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.06	0.07	0.07
3150	0.04	0.04	0.04	0.04	0.05	0.05	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.06	0.07	0.07	0.07	0.07	0.07	0.07
4000	0.05	0.05	0.05	0.05	0.06	0.06	0.06	0.06	0.06	0.06	0.07	0.07	0.07	0.07	0.07	0.08	0.08	0.08	0.08	0.08	0.08
5000	0.07	0.07	0.08	0.08	0.08	0.08	0.08	0.08	0.08	0.09	0.09	0.09	0.09	0.09	0.09	0.10	0.10	0.10	0.10	0.10	0.10
6300*	n/a																				
8000*	n/a																				
10000*	n/a																				

Practical sound absorption coefficient measurements, α_p

Measured practical sound absorption coefficient, α_p																				
0.00	0.05	0.10	0.15	0.20	0.25	0.30	0.35	0.40	0.45	0.50	0.55	0.60	0.65	0.70	0.75	0.80	0.85	0.90	0.95	1.00

f, Hz	Expanded uncertainties $\pm U$ (k=2) Derived from BS EN ISO 12999-2:2020 based on repeatability conditions and a coverage factor of k=2																				
	63*	n/a																			
125																					
250	0.02	0.02	0.03	0.03	0.03	0.04	0.04	0.04	0.05	0.05	0.05	0.06	0.06	0.07	0.07	0.07	0.08	0.08	0.08	0.09	0.09
500	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
1000	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
2000	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05	0.05
4000	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06	0.06
8000*	n/a																				

Equivalent sound absorption area of the test specimen, A_T

Measured equivalent sound absorption area, A_T , m ²																				
0.0	0.5	1.0	1.5	2.0	2.5	3.0	3.5	4.0	4.5	5.0	5.5	6.0	6.5	7.0	7.5	8.0	8.5	9.0	9.5	10.0

f, Hz	Expanded uncertainties $\pm U$ (k=2) Derived from BS EN ISO 12999-2:2020 based on repeatability conditions and a coverage factor of k=2																				
	n/a																				
50*	n/a																				
63*	0.2	0.5	0.7	1.0	1.3	1.5	1.8	2.1	2.3	2.6	2.9	3.2	3.4	3.7	4.0	4.2	4.5	4.8	5.0	5.3	5.6
80*	0.2	0.4	0.6	0.8	1.0	1.2	1.4	1.6	1.8	2.0	2.2	2.4	2.6	2.8	3.0	3.2	3.3	3.5	3.7	3.9	4.1
100	0.2	0.3	0.5	0.6	0.8	0.9	1.0	1.2	1.3	1.5	1.6	1.8	1.9	2.1	2.2	2.3	2.5	2.6	2.8	2.9	3.1
125	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3
160	0.2	0.3	0.3	0.4	0.5	0.6	0.7	0.8	0.9	0.9	1.0	1.1	1.2	1.3	1.4	1.4	1.5	1.6	1.7	1.8	1.9
200	0.2	0.2	0.3	0.4	0.4	0.5	0.6	0.6	0.7	0.8	0.8	0.9	1.0	1.0	1.1	1.2	1.2	1.3	1.4	1.4	1.5
250	0.2	0.2	0.3	0.3	0.4	0.5	0.5	0.6	0.6	0.7	0.7	0.8	0.8	0.9	0.9	1.0	1.0	1.1	1.2	1.2	1.3
315	0.2	0.2	0.3	0.3	0.4	0.4	0.5	0.5	0.5	0.6	0.6	0.7	0.7	0.8	0.8	0.9	0.9	0.9	1.0	1.0	1.1
400	0.2	0.2	0.3	0.3	0.3	0.4	0.4	0.4	0.5	0.5	0.5	0.6	0.6	0.6	0.7	0.7	0.8	0.8	0.8	0.9	0.9
500	0.2	0.2	0.2	0.3	0.3	0.3	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.7	0.7	0.7	0.8	0.8
630	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.7	0.7	0.7
800	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.7
1000	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.7
1250	0.2	0.2	0.2	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.7
1600	0.2	0.2	0.3	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.6	0.6
2000	0.3	0.3	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.7	0.7
2500	0.3	0.3	0.3	0.4	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.7	0.7
3150	0.4	0.4	0.4	0.4	0.5	0.5	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.7
4000	0.5	0.5	0.5	0.5	0.6	0.6	0.6	0.6	0.6	0.6	0.7	0.7	0.7	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8
5000	0.7	0.7	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.9	0.9	0.9	0.9	0.9	0.9	1.0	1.0	1.0	1.0	1.0	1.0
6300*	n/a																				
8000*	n/a																				
10000*	n/a																				

Appendix D – Mounting Methods

Description of Test Specimen Mountings for Sound Absorption Tests

BS EN ISO 354:2003 describes various test specimen mountings. The methods of mounting used for these tests is briefly described as follows:

Type A Mounting

Test specimen placed directly against a room surface. The specimen may be held in place with adhesive or mechanical fasteners providing there is no resulting air space between the specimen and room surface.



0444

This report shall not be reproduced,
except in full, without written approval of
SRL Technical Services Limited

Laboratory

Holbrook House
The Street
Little Waldingfield
Sudbury
Suffolk
CO10 0TF
Tel: +44 (0)1787 247595

Website: www.srltst.com
e-mail: srl@srltst.com

Registered Name and Address:

SRL Technical Services Limited
Holbrook House
Little Waldingfield
Sudbury
Suffolk
CO10 0TF

Registered Number: 907694 England

